

Flat Concrete Substrate




Sound Tested in Accordance
with ASTM E90-09

PT3 - Shaft Wall Concrete

Fire Rated Gasket (FRG) - UL Listing: [HW-D-0889](#)

Fire Rated	Strip Width	Max. Joint Protection
FRG-75	1.00"	.75"
FRG-100	1.25"	1.00"
FRG-150	1.75"	1.50"
FRG-200	2.25"	2.00"



1. Installed Gap - Single Story (compression only) = **Deflection for Joint Protection**
2. Installed Gap - Multi-Story (compress + extension) = **1/2 distance** of **Deflection for Joint Protection**
3. Attach Track profile to substrate with approved fastener max 24" O.C or per E.O.R.
4. Drywall fastenes max 3" below track flanges
5. Fire Rated (FRG) install and overlap per UL listed assembly or Safti-Seal install guide

UL, ASTM & Code Standards

UL2079 (5th Edition) & CAN/ULC S115
ASTM E814, E1966, E2837
A1003, A653, A924, C645, C754, C955
Sound Tested according to ASTM E90-09
2012 & 2015 IBC

Leed Points

MR 2.1 & 2.2 - Construction Waste: up to 2pts
MR 4.1 & 4.2 - Recycled Content: up to 2 pts
MR 5.1 & 5.2 - Regional Proximity
EQ 4.1 - Low Emitting Materials
EQ 9 - Enhanced Acoustical

Phone: (425) 869-2811 Fax: (425) 869-2300
U.S. Patent #10,626,598

www.saftiseal.com