



Install Guide & Tips – Conduit Penetration with Sealant

Safti-Seal Penetration Fire Stop

Where a pipe, conduit, cable, etc... penetrates through Safti-Seal FRG Joint Protection and it is assumed the penetration will "cycle" with substrate. To maintain a continuous smoke, sound, and fire rated assembly around penetration through Safti-Seal FRG:

- 1) Annular space left in gypsum around penetration must be of a size to accommodate a "caulk seal" considering encumbrance and elasticity rating of caulk used to fill annular space (caulk may reduce movement capability provided by Safti-Seal FRG)
- 2) Caulk used is a non-solvent based material
- 3) Install of caulk is per manufacturer's instructions and based on material penetrating joint assembly

